

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove

Longton

Stoke - on - Trent

Staffordshire

ST3 5TX

Account Ref: 13713-0499-0001



This is to certify that equipment listed and stickered has undergone and passed the Electrical and/or Visual Tests according to the Electricity at Work Standards Regulations (P.A.T)



Certificate Valid Until 9th January 2014

Testing Carried Out By Kevin J Spencer
Best Test UK Unit 1
Elswick Road
Fenton Industrial Estate
Fenton
Stoke On Trent
ST4 2PZ
07854 016320
www.best-test-uk.co.uk
info@best-test-uk.co.uk

Signed..... *K.J. Spencer*
Date..... *10/1/13*

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Sound										
Dee Rack - Amps	3	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Mixer	FSM1	10.01.13	09.01.14	P	S	0.23	199.00	S	S	PASS
Numark HDI Player	HDI1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Dee Rack - Amps	2	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Dee Rack - Mixer	16	10.01.13	09.01.14	P	S	0.21	199.00	S	S	PASS
Dee Rack - Amps	5	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Dee Rack - Amps	4	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
Dee Rack - Amps	3	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Dee Rack - Amps	1	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Dee Rack - Amps	10	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Dee Rack - Mixer	15	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Radio Microphone	BETA87	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
Dee Rack - Daytime system	14	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Denon DN4000CD Player	1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Dave Dee The Complete Disco Service LTD Lighting Control										
Lighting Controller	CT-400S	10.01.13	09.01.14	P	S	0.21	199.00	S	S	PASS
Lighting Controller	SC4000E	10.01.13	09.01.14	P	S	0.09	199.00	S	S	PASS
Dee Rack - Lighting	11	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
Lighting Controller	EURO4E	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Dee Rack - Lighting	12	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Abstract Lighting Controller	XP1	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Lighting Control Continued										
LED Controller	1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Dee Rack - Lighting	14	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Octopar Controller	1	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Dave Dee The Complete Disco Service LTD Lighting Effects										
Work Light	LIGHT1	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Twister HP4	1	10.01.13	09.01.14	P	S	0.09	199.00	S	S	PASS
Twister HP4	2	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Twister HP4	3	10.01.13	09.01.14	P	S	0.10	199.00	S	S	PASS
Twister HP4	4	10.01.13	09.01.14	P	S	0.09	199.00	S	S	PASS
Twister HP4	5	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Par 56 Bar	BAR 1	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Par 56 Bar	BAR 2	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Par 56 Bar	BAR 3	10.01.13	09.01.14	P	S	0.21	199.00	S	S	PASS
Par 56 Bar	BAR 4	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Par 56 Bar	BAR 5	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
Par 56 Bar	BAR 6	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Preditor HX Scanner	PRED HX1	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Preditor HX Scanner	PRED HX2	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Preditor HX Scanner	PRED HX3	10.01.13	09.01.14	P	S	0.09	199.00	S	S	PASS
Preditor HX Scanner	PRED HX4	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Preditor HX Scanner	PRED HX5	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Lighting Effects Continued										
Preditor HX Scanner	PRED HX6	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
Acme Spotknight Moving Head	MH1	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Acme Spotknight Moving Head	MH2	10.01.13	09.01.14	P	S	0.10	199.00	S	S	PASS
Acme Spotknight Moving Head	MH3	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
Acme Spotknight Moving Head	MH4	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Acme Spotknight Moving Head	MH5	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Acme Spotknight Moving Head	MH6	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Par 64 LED Can	1	10.01.13	09.01.14	P	S	0.22	199.00	S	S	PASS
Par 64 LED Can	2	10.01.13	09.01.14	P	S	0.19	199.00	S	S	PASS
Par 64 LED Can	3	10.01.13	09.01.14	P	S	0.09	199.00	S	S	PASS
Par 64 LED Can	4	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Par 64 LED Can	5	10.01.13	09.01.14	P	S	0.19	199.00	S	S	PASS
Par 64 LED Can	6	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Par 64 LED Can	7	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Par 64 LED Can	8	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
Par 64 LED Can	9	10.01.13	09.01.14	P	S	0.21	199.00	S	S	PASS
Par 64 LED Can	10	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
Par 64 LED Can	11	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Par 64 LED Can	12	10.01.13	09.01.14	P	S	0.22	199.00	S	S	PASS
Par 64 LED Can	13	10.01.13	09.01.14	P	S	0.21	199.00	S	S	PASS
Par 64 LED Can	14	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Lighting Effects Continued										
Par 64 LED Can	15	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Par 64 LED Can	16	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Par 64 LED Can	17	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Par 64 LED Can	18	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Par 64 LED Can	19	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Par 64 LED Can	20	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
DJ Booth Starcloth	1	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
DJ Booth Starcloth	2	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Starcloth Backdrop	1-4mx3m	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Starcloth Backdrop	2-3mx2m	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
1m LED Bar	1	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
1m LED Bar	2	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
1m LED Bar	3	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
1m LED Bar	4	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
1m LED Bar	5	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
1m LED Bar	6	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
1m LED Bar	7	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
1m LED Bar	8	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
1m LED Bar	9	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
1m LED Bar	10	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
1m LED Bar	11	10.01.13	09.01.14	P	S	0.10	199.00	S	S	PASS

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Lighting Effects Continued										
Cluster Laser	1	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Cluster Laser	2	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
Cluster Laser	3	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Cluster Laser	4	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Kam ILink Blue 500	1	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Kam ILink Green	1	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
Equinox Atria	1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Equinox 1500W Power Strobe	1	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Equinox 80W Strobe	1	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Prolight MiracLED	1	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
Prolight MiracLED	2	10.01.13	09.01.14	P	S	0.18	199.00	S	S	PASS
Prolight MiracLED	3	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Prolight MiracLED	4	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Moving Head Laser	1	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
Moving Head Laser	2	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Pro Light XL Flame Machine	1	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Pro Light XL Flame Machine	2	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Pro Light XL Flame Machine	3	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Pro Light XL Flame Machine	4	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Future Light 250 Discharge	1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Future Light 250 Discharge	2	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Effects										
Vision(NEC) 42" Plasma Screen	1	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
Vision(NEC) 42" Plasma Screen	2	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Chauvet Bubble Machine	1	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
Chauvet Bubble Machine	2	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Sanyo Projector	1	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Sanyo Projector	2	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Amstrad DVD Player	1	10.01.13	09.01.14	P	S	0.18	199.00	S	S	PASS
SVGA Monitor Splitter Switch Box	1	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
4 Port SVid Splitter Box	1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
Compaq Laptop	1	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS
Vision 19" Flat screen Monitor	1	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
16" Mirror Ball Motor	1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
16" Mirror Ball Motor	2	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
Martin Jem Smoke Machine	1	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
Martin Jem Smoke Machine	2	10.01.13	09.01.14	P	S	0.19	199.00	S	S	PASS
1.5m UV Tube Light	1	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
1.5m UV Tube Light	2	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
Dave Dee The Complete Disco Service LTD Power/Cables										
Mains Distribution Board	MB1	10.01.13	09.01.14	P	S	0.10	199.00	S	S	PASS
1.5m IEC	1	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
1.5m IEC	2	10.01.13	09.01.14	P	S	0.06	199.00	S	S	PASS

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Power/Cables Continued										
1.5m IEC	3	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
1.5m IEC	4	10.01.13	09.01.14	P	S	0.07	199.00	S	S	PASS
1.5m IEC	5	10.01.13	09.01.14	P	S	0.03	199.00	S	S	PASS
1.5m IEC	6	10.01.13	09.01.14	P	S	0.05	199.00	S	S	PASS
1.5m IEC	7	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
1.5m IEC	8	10.01.13	09.01.14	P	S	0.06	199.00	S	S	PASS
1.5m IEC	9	10.01.13	09.01.14	P	S	0.09	199.00	S	S	PASS
1.5m IEC	10	10.01.13	09.01.14	P	S	0.05	199.00	S	S	PASS
1.5m IEC	11	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
1.5m IEC	12	10.01.13	09.01.14	P	S	0.06	199.00	S	S	PASS
1.5m IEC	13	10.01.13	09.01.14	P	S	0.07	199.00	S	S	PASS
1.5m IEC	14	10.01.13	09.01.14	P	S	0.03	199.00	S	S	PASS
1.5m IEC	15	10.01.13	09.01.14	P	S	0.05	199.00	S	S	PASS
1.5m IEC	16	10.01.13	09.01.14	P	S	0.06	199.00	S	S	PASS
1.5m IEC	17	10.01.13	09.01.14	P	S	0.06	199.00	S	S	PASS
1.5m IEC	18	10.01.13	09.01.14	P	S	0.07	199.00	S	S	PASS
1.5m IEC	19	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
1.5m IEC	20	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
4m 2 Way Extension Cable	1	10.01.13	09.01.14	P	S	0.05	199.00	S	S	PASS
4m 2 Way Extension Cable	2	10.01.13	09.01.14	P	S	0.06	199.00	S	S	PASS
4m 2 Way Extension Cable	3	10.01.13	09.01.14	P	S	0.03	199.00	S	S	PASS

Dave Dee The Complete Disco Service LTD

16 Waterdale Grove
Stoke - on -Trent
Staffordshire ST3 5TX

Testing Carried Out By K J Spencer

C/o Best Test UK Unit 1
Elswick Road Fenton Industrial Estate
Fenton Stoke on Trent ST4 2PZ

Account Ref: 13713-0499-0001



info@best-test-uk.co.uk
www.best-test-uk.co.uk
07854 016320

Appliance Description	Appliance ID	Date Tested	Retest Date	Visual Check	Polarity Check	Earth Cont Ohms	Insulation MOhms	Load kVA	Leakage mA	Status
Dave Dee The Complete Disco Service LTD Power/Cables Continued										
4m 2 Way Extension Cable	4	10.01.13	09.01.14	P	S	0.05	199.00	S	S	PASS
4m 2 Way Extension Cable	5	10.01.13	09.01.14	P	S	0.08	199.00	S	S	PASS
4m 2 Way Extension Cable	6	10.01.13	09.01.14	P	S	0.05	199.00	S	S	PASS
4m 2 Way Extension Cable	7	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
4m 2 Way Extension Cable	8	10.01.13	09.01.14	P	S	0.07	199.00	S	S	PASS
4m 2 Way Extension Cable	9	10.01.13	09.01.14	P	S	0.04	199.00	S	S	PASS
10m 4 Way Extension Cable	1	10.01.13	09.01.14	P	S	0.08	199.00	S	S	PASS
10m 4 Way Extension Cable	2	10.01.13	09.01.14	P	S	0.10	199.00	S	S	PASS
10m 4 Way Extension Cable	3	10.01.13	09.01.14	P	S	0.08	199.00	S	S	PASS
10m 4 Way Extension Cable	4	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
5m 6 Way Extension Cable	1	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
5m 6 Way Extension Cable	2	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
30m 16 Amp Extension Cable	1	10.01.13	09.01.14	P	S	0.15	199.00	S	S	PASS
30m 16 Amp Extension Cable	2	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
30m 16 Amp Extension Cable	3	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
30m 16 Amp Extension Cable	4	10.01.13	09.01.14	P	S	0.14	199.00	S	S	PASS
30m 32 Amp Extension Cable	1	10.01.13	09.01.14	P	S	0.16	199.00	S	S	PASS
2m 32A - 2x16 Amp Splitter Cable	1	10.01.13	09.01.14	P	S	0.17	199.00	S	S	PASS
5m 13A -16 Amp Extension Cable	1	10.01.13	09.01.14	P	S	0.12	199.00	S	S	PASS
16 inch Portable Fan	1	10.01.13	09.01.14	P	S	0.11	199.00	S	S	PASS
16 inch Portable Fan	2	10.01.13	09.01.14	P	S	0.13	199.00	S	S	PASS